

SMC/ISD (ICCC) /OD/No.: [288](#)

 Date: [03/07/2024](#)

Dear Sir/Madam,

Sub.: Quotation for Supply & Support of Portable UPS [SSCDL-Network-01-2024]

Quotation is hereby invited for Supply & support of Portable UPS latest by meeting the below mentioned minimum specifications.

Item No.	Description and Minimum Specification	Compliance Yes/No	Deviation from Specification /Remarks if Any
A	B	C	D
Minimum specification for Portable Tower UPS			
1.	Input		
	• Should Support 230 V Main Input Voltage		
	• Should have 50/60 Hz +/- 5 Hz auto-sensing frequency		
	• Should support 170...294 +/- 5V Input voltage variation.		
	Output		
	• Should support 600W capacity.		
	• Should support 50 Hz frequency on battery		
	• Transfer time on battery should be 3-8 ms typical		
	Protection and Filtering		
	• Must have Full time AC surge Protection		
	• Should have Input Circuit Breaker		
	Battery		
	• 12V, 7.2 Ah x 2 Must be supplied with product from day one so that In-built Battery to provide min 30 minutes of Backup time.		
	• Should have 3-7 Hrs of Recharge Time		
	• Battery Should be replaceable whenever required.		
	Physical Specs		
	• Should Support 0 to 40 °C temperature for operation.		
• Product Should be BIS Certified.			
• Should have minimum 3 Power Outlets with battery backup and surge protection			
• Should have minimum 1.5 Meter of Power Cord			

	<ul style="list-style-type: none"> • Warranty 		
	<ul style="list-style-type: none"> • Minimum 2 Years of Comprehensive repair or replacement Warranty with parts, modules, software and battery. 		
	<ul style="list-style-type: none"> • Proposed Make: 		
	<ul style="list-style-type: none"> • Proposed Model/Part Code: 		

Note:

1. Quotation once offered shall not be withdrawn.
2. Quotation once accepted shall be binding to the selected agency.
3. Right to accept any or to reject any or all the quotations without assigning any reason thereof is reserved by the competent authority of SSCDL/SMC.
4. **Sealing, marking and submission of the Quotation:** Documents shall be submitted in Hard Copy to Surat Smart City Development Limited/SMC by the Bidder as per below:
Quotation/Bid Documents shall be put in an envelope containing All Technical Documents, Product Technical Datasheets along with the Price Bid as per format defined in Quotation Document.

The envelope must be sealed and super scribed and must be sent as under:

Details to be mentioned exactly on sealed envelop	
<p>TENDER DETAILS</p> <ul style="list-style-type: none"> • Notice No.: SSCDL-Network-01-2024 • Supply and Support of Portable UPS • Last date of Submission: 11/07/24 up to 18:00 hrs. 	<p>To, The Chief Accountant, Surat Municipal Corporation, Mahanagar Seva Sadan, Gordhandas Chokhawala Marg, Muglisara, Surat - 395 003, Gujarat, INDIA.</p>

The envelope must be sent **strictly by Postal Speed Post or Registered Post AD** only so as to reach on or before **11/07/24 up to 18:00 hrs. Quotations received in any other manner or mode (like courier, in person, etc.) will not be considered. SSCDL/SMC won't be responsible for postal delays.**

6. Delivery: Within 15 working days of issuance of work order.
8. Payment: 100% payment will be released after satisfactory completion of supply work and submission of invoice within 30 days.
9. The contractor will submit the invoice to the Surat Smart City Development Limited having GSTIN 24AAWCS9229G1ZR mentioned therein.

Sd/-
General Manager (IT)
Surat Smart City Development Ltd.

PRICE BID

The price quoted should be inclusive of all (including capital expenditure cost, installation, commissioning and maintenance charges, equipment cost, etc.) except the applicable taxes/GST.

#	Description	Make, Model, Part Code	Qty.	Unit Rate (INR)	GST (%)	Amount/Unit with GST (INR)
A	B	C	D	E	F	G=E+(E*F)
1.	1000VA/600W Tower Portable UPS		1			
Grand Total						

Name of Organization:			
Address:			
Details of Authorized Person Signing this Quotation			
Name:		Contact No:	
Designation:		Email Address:	
Date:		Company Stamp:	